

The influence of percentage share of municipal landfill leachates in a mixture with synthetic wastewater on the effectiveness of a treatment process with use of a membrane bioreactor

E. Puszczalo*, J. Bohdziewicz, A. Świerczyńska

*Institute of Water and Wastewater Engineering, Silesian University of Technology, ul. Konarskiego 18, 44-100 Gliwice, Poland
Tel. +48 (32) 2372981; Fax +48 (32) 2371047; email: ewa.puszczalo@polsl.pl*

Received 11 June 2009; Accepted 1 December 2009

ABSTRACT

The investigations were focused on the determination of the most favorable amount of leachates treated along with a synthetic sewage in a membrane bioreactor. The leachates percentage share was changed over a range of 3–40 vol%. COD and BOD₅ of the leachates varied from 3,000 to 3,500 mg/dm³ and from 170 to 280 mg/dm³ respectively. The leachates were characterized by a high concentration of ammonia nitrogen (over 1,000 mg/dm³) and low BOD₅/COD ratio (0.06 in average), which indicated their negligible susceptibility to biodegradation. The concentration of activated sludge in the membrane bioreactor was maintained within 3.5–4.0 g/dm³, the sludge load with contaminants reached the level of 0.1 g COD/g_{DM}·d while the oxygen concentration in the aeration tank was 4.0 mg O₂/dm³. The system operated in a 12-h cycle. The degree of impurities removal was assessed analyzing changes in the following indicators: COD, BOD₅, TOC, N-NO₃⁻, N-NH₄⁺, P_{tot}. The results revealed that the volume of leachates in the treated mixture of sewage should not exceed 10 vol%. All the tests showed a decrease in COD and BOD₅ of around 90%. The only indicator which exceeded the permissible value was nitrate nitrogen. Thus, the leachates purified by activated sludge were additionally treated by reverse osmosis.

Keywords: Membrane bioreactor; Landfill leachate; Activated sludge; Reverse osmosis

* Corresponding author.