



## Nanofiltration as pretreatment for scale prevention in seawater reverse osmosis desalination

Laia Llenas<sup>a,d\*</sup>, Xavier Martínez-Lladó<sup>a</sup>, Andriy Yaroshchuk<sup>b,c</sup>, Miquel Rovira<sup>a,c</sup>,  
Joan de Pablo<sup>a,c</sup>

<sup>a</sup>CTM – Centre Tecnològic, Av. Bases de Manresa 1, 08242 Manresa, Spain

Tel.: +34938777373; fax: +34938777374; email: laia.llenas@ctm.com.es

<sup>b</sup>ICREA, Polytechnic University of Catalonia, Av. Diagonal 647, 08028 Barcelona, Spain

<sup>c</sup>Department of Chemical Engineering, Polytechnic University of Catalonia, Av. Diagonal 647, 08028 Barcelona, Spain

<sup>d</sup>Department of Mining Engineering and Natural Resources, Polytechnic University of Catalonia, Av Bases de Manresa 61, 08242 Manresa, Spain

Received 4 March 2011; accepted 15 May 2011

---

### ABSTRACT

Seawater contains high concentrations of sparingly soluble salts which can cause scaling of the membrane surface, which in turn can limit the productivity and water recovery potential of seawater reverse osmosis (SWRO). Nanofiltration (NF) pre-treatment of seawater can prevent scaling via preferential removal of scale-forming ions. Several studies have shown that the rejection of scale-forming ions can vary considerably depending on the membrane. The main objective of this study was to test a number of commercially available NF membranes with synthetic seawater in order to compare their performance and identify optimum membranes and operational conditions for the removal of compounds that are known to cause scaling ( $\text{CaSO}_4$  (s),  $\text{Mg}(\text{OH})_2$ ,  $\text{CaCO}_3$  (s), etc.) in SWRO. Six membranes, supplied by several manufacturers, were tested in a laboratory-scale plant at various trans-membrane pressure differences. For the majority of membranes, the sulphate rejection was superior at 90%, which is very important for the prevention of scaling. Following on from the obtained results, a selection of the most suitable membranes for scaling prevention in seawater desalination can be done.

**Keywords:** Nanofiltration; Scale prevention; Desalination; Atomic force microscopy

---

---

\*Corresponding author