



Construction and validation of a long-channel membrane test cell for representative monitoring of performance and characterization of fouling over the length of spiral-wound membrane modules

Nadine Siebdrath^a, Wei Ding^a, Elisabeth Pietsch^a, Joop Kruithof^b, Wolfgang Uhl^{a,c,*}, Johannes Vrouwenvelder^{b,d,e}

^aTechnische Universität Dresden, Chair of Water Supply Engineering, 01062 Dresden, Germany

^bWetsus, European Centre of Excellence for Sustainable Water Technology, Oostergoweg 9, 8911 MA Leeuwarden, The Netherlands

^cNorwegian Institute for Water Research (NIVA), Gaustadalléen 21, 0349 Oslo, Norway, Tel. +47-40 10 66 55; Fax: +47-22 18 52 00; email: wolfgang.uhl@niva.no (W. Uhl)

^dKing Abdullah University of Science and Technology (KAUST), Water Desalination and Reuse Center (WDRC), Division of Biological and Environmental Science and Engineering (BESE), Thuwal 23955-6900, Saudi Arabia

^eDelft University of Technology, Faculty of Applied Sciences, Department of Biotechnology, Van der Maasweg 9, 2629 HZ Delft, The Netherlands

Received 28 February 2017; Accepted 20 June 2017

ABSTRACT

A long-channel membrane test cell (LCMTC) with the same length as full-scale elements was developed to simulate performance and fouling in nanofiltration and reverse osmosis spiral-wound membrane modules (SWMs). The transparent LCMTC enabled simultaneous monitoring of SWM performance indicators: feed channel pressure drop, permeate flux and salt passage. Both permeate flux and salt passage were monitored over five sections of the test cell and were related to the amount and composition of the accumulated foulant in these five sections, illustrating the unique features of the test cell. Validation experiments at various feed pressures showed the same flow profile and the same hydraulic behaviour as SWMs used in practice, confirming the representativeness and suitability of the test cell to study SWM operation and fouling. The importance to apply feed spacers matching the flow channel height in test cell systems was demonstrated. Biofouling studies showed that the dosage of a biodegradable substrate to the feed of the LCMTC accelerated the gradual decrease of membrane performance and the accumulation of biomass on the spacer and membrane sheets. The strongest permeate flux decline and the largest amount of accumulated biomass was found in the first 18 cm of the test cell. The LCMTC showed to be suitable to study the impact of biofilm development and biofouling control strategies under representative conditions for full-scale membrane elements.

Keywords: Feed spacer; RO spiral-wound module; NF; Permeate production; Membrane performance; Biofouling

* Corresponding author.