

## Levelized cost analysis for desalination using renewable energy in GCC

Hassan K. Abdulrahim\*, Mansour Ahmed

Water Research Center, Kuwait Institute for Scientific Research, P.O. Box: 24885, 13109 Safat, Kuwait, Tel. +965 9669 0551;  
email: habdulrahim@kisir.edu.kw (H.K. Abdulrahim)

Received 28 February 2022; Accepted 12 April 2022

### ABSTRACT

Seawater desalination plants are considered the main source of fresh water in most of the GCC countries. Desalination is an energy-intensive process, where energy price represents more than 44% of the cost of desalinated water. Almost all commercial desalination plants rely on fossil fuel to secure the energy requirements either in thermal or electrical form. GCC countries are gifted with consistent and predictable solar energy that can be used to power the desalination processes and to improve their sustainability and to reduce their environmental impacts. Solar energy can be harvested using photovoltaics (PV) panels or different forms of concentrated solar power. In this paper, the energy cost in the form of levelized cost of energy (LCOE) was calculated for a PV solar energy generation plant and hence, the levelized cost of water (LCOW) for a reverse osmosis reference desalination plant in the six GCC countries had been estimated and compared. System Advisor Model (SAM) is a comprehensive renewable energy analysis software developed by the National Renewable Energy Laboratory and is used in this work. SAM relies on the metrological weather data for the evaluation of solar energy. The included financial model within SAM was used to estimate the LCOE and the Power Purchase Agreement price. A reference reverse osmosis desalination plant of a capacity of 400,000 m<sup>3</sup>/d (88 MIGD) has been used in this study. The power consumption of the plant is estimated as 76 MW at 4.56 kWh/m<sup>3</sup>. A photovoltaic power plant of capacity 76 MW was designed and the LCOE produced by this plant was estimated. The LCOE was different according to the PV plant location in GCC countries. The obtained LCOE is used to estimate the LCOW produced by this plant using Desalination Economic Evaluation Program software. The LCOE for the studied locations ranged from 8.46 to 9.11 ¢/kWh (1.0 USD \$ = 100 ¢), and the LCOW ranged from 103.0 to 105.0 ¢/m<sup>3</sup>, compared to 10.737 ¢/kWh and 110.1 ¢/m<sup>3</sup> for the conventional combined cycle power plant.

**Keywords:** Levelized cost of energy (LCOE); Levelized cost of water (LCOW); Desalination processes; Renewable energy; Solar desalination; System Advisor Model (SAM); Desalination Economic Evaluation Program (DEEP)

### 1. Introduction

Renewable energy can play a vital role in desalination. Renewable technologies suited to desalination include solar thermal, solar photovoltaics, wind, and geothermal energy [1,2]. Solar technologies based on solar heat concentration, notably concentrating solar power, produce a large amount

of heat and is suited to thermal desalination. Photovoltaic (PV) and wind electricity are often combined with membrane desalination units (reverse osmosis, electrodialysis). As electricity storage is still a challenge, combining power generation and water desalination can be a cost-effective storage option when generation exceeds demand.

\* Corresponding author.

Presented at the 14th Gulf Water Conference: Water in the GCC... Towards Economic Efficiency and Financial Sustainability, 13–15 February 2022, Riyadh, Saudi Arabia

1944-3994/1944-3986 © 2022 Desalination Publications. All rights reserved.

Renewable energy-based desalination provides a sustainable way for freshwater production. In the past decade, the cost of renewable desalination was higher than that of conventional desalination based on fossil fuels for energy input [1,2]. However, solar desalination is expected to become economically attractive as renewable technologies' costs continue to decline, and the prices of fossil fuels continue to increase. Using locally available renewable energy resources for desalination is likely to be a cost-effective solution, particularly in remote regions, with low population density and inadequate infrastructure for fresh water and electricity transmission and distribution [3].

## 2. Methodology

The key factor for utilizing renewable energy sources in desalination is the overall cost of freshwater production. The levelized cost of water (LCOW) represents the average cost for water production over the project life. The energy cost is presented by the levelized cost of energy (LCOE) and is used in the calculation of the energy cost in water. In this work, a reference desalination plant was selected for this investigation, as shown in Table 1. This plant was mainly operated using combined cycle power plants (CCPP). The LCOW of this plant is first evaluated based on the energy produced by CCPP. The required power for this desalination plant was estimated and then provided by a renewable energy power plant (REPP). The LCOE of these REPP was evaluated based on the latest cost of renewable energy equipment. The LCOE of the REPP is then used to estimate the LCOW based on renewable energy. Renewable energy sources are particularly site-dependent, and for this reason, the study includes an investigation of REPP in different GCC countries; Bahrain, Kuwait, Oman, Qatar, Saudi Arabia, the United Arab Emirates, for comparison, Fig. 1.

The power needed for this desalination plant was estimated using the average specific energy consumption according to the technology type and plant capacity, among

other parameters. The Desalination Economic Evaluation Program (DEEP) 5.13 software [5,6] was used to estimate the power and the LCOW based on the CCPP. DEEP estimates the LCOE of the combined cycle and uses this value to evaluate the LCOW. The combined gas-steam cycle was used with oil as the fuel. However, the LCOE using REPP is calculated and plugged into DEEP to evaluate the LCOW using renewable energy. System Advisor Model (SAM) software [7–9] was used to evaluate the LCOE of the REPP. SAM uses design DNI value from the weather data file along with other design parameter values to determine the nominal capacities of the solar field and other components in the system. The design DNI is different from the hourly DNI values in the weather file. The design DNI is used to calculate the nameplate capacities. For the reference reverse osmosis

Table 1  
Reference desalination plants [4]

|                   | Shuaiba-4                 |
|-------------------|---------------------------|
| Status            | Construction              |
| Location          | Shuaiba, Saudi Arabia     |
| Location type     | Land-based                |
| Technology        | Reverse osmosis           |
| No. of passes     | Two-pass                  |
| Pretreatment      | Dual media filtration     |
| No. of units      |                           |
| Max. brine temp.  | Atm. temp.                |
| Feedwater type    | Seawater                  |
| Capacity          | 400,000 m <sup>3</sup> /d |
| Online date       | 2020                      |
| Award date        | 2017                      |
| User category     | Municipalities            |
| Est. EPC cost     | SAR 1,600,000,000         |
| Est. project cost |                           |




Fig. 1. GCC countries.

desalination plant, the required electric power is 76 MW. A photovoltaic power plant (PVPP) of capacity 76 MW was designed, and the LCOE is evaluated using SAM software as explained above.

### 3. Photovoltaic power plant economics

A 76 MW<sub>net</sub> output capacity PVPP was designed using SAM 2020.11.29 software. The design steps started with choosing the PVPP location and specifying the weather data file. In this study, we downloaded the required weather data files from OneBuilding [10]. Details presented here are for PVPP using weather data obtained from Kuwait International Airport. The next step in the design procedure was to select the PV module and inverter. SunPower SPR-E19-310-COM PV panels were selected for this plant. The module's nominal efficiency was 19%, and the maximum DC power produced based on the reference conditions of 1,000 W/m<sup>2</sup> and PV cell temperature of 25°C was 310 W<sub>dc</sub>. Other specifications of the module, along with the characteristics curve, are shown in Fig. 2.

A Power Electronics FS0450PU inverter was selected for this system; specifications and characteristics of the inverter

is shown in Fig. 3. The next step was to size the system based on the needed capacity. SAM provides two methods for sizing the system, and we chose the automated estimation of the system configuration method.

For the case of Kuwait International Airport data, the following system sizing results were obtained from SAM.

Nameplate DC capacity: 91,198 kW<sub>dc</sub>  
 Total AC capacity: 76,050 kW<sub>ac</sub>  
 Total inverter DC capacity: 78,826 kW<sub>dc</sub>  
 Number of modules: 294,048  
 Number of strings: 24,504  
 Total module area: 479,592 m<sup>2</sup>  
 String V<sub>oc</sub> at reference conditions (V): 772.8  
 String V<sub>mp</sub> at reference conditions (V): 656.4

The next step was to estimate the system cost. The cost of the modules and inverters, along with the balance of system (BOS) equipment, are evaluated from ATB [11], and supplied into SAM, Fig. 4. The total direct capital cost was 78,522,072 \$.

The indirect capital cost includes the permitting and environmental studies, engineering, and development overhead




Fig. 2. SunPower PV module characteristics.




Fig. 3. Power electronics inverter characteristics.

along with the land cost, as shown in Fig. 5. It is worth mentioning that the sales tax is omitted in this study as it is not applied in many GCC countries.

For the PVPP in Kuwait, the total indirect cost was estimated to be 15,503,777 \$, which results in a total installation cost equal to 94,025,848 \$, and the cost per kW of the capacity was 1,133.0 \$/kW. The project was financed by a loan for 60% of the cost of the total installed capacity, with an inflation rate of 2.5%/y and discount rate of 10%/y, project lifetime of 25 y, and no taxes. The LCOE of this plant was estimated at 9.045 ¢/kWh. For the private sector to be involved in these projects, the electricity was usually sold to the national grid authority according to a Power Purchase Agreement (PPA) price. For an internal rate of return (IRR) of 11% at the 20th year, the PPA was estimated to 9.102 ¢/kWh. This was the value that has been used in the evaluation of the LCOW using DEEP software. Table 2 shows a summary of the results obtained by SAM for the PVPP in different locations in GCC countries.

In Table 2, the real levelized cost is a constant dollar, inflation-adjusted value, while the nominal LCOE is a current dollar value, the same definition for the real and nominal PPA prices is applied [7]. LCOE is the total value of energy costs divided by the total energy generated. For the evaluation of the LCOW, the nominal PPA prices were

used. The net present value (NPV) in Table 2 represents the time value of money and a discount rate for the cash flows, while the IRR is the discount rate that causes the NPV of electricity investments to become zero [12].

The values of the nominal PPA prices from Table 2 were used to calculate the LCOW using DEEP software, Table 3. For the conventional CCPP, the LCOE were estimated at 10.737 ¢/kWh, which was resulted in an LCOW of 1.1014 \$/m<sup>3</sup>, which was higher than all the values in Table 3.

Kuwait International Airport was not the optimum location for a PVPP. Two further sites in Kuwait were also studied for choosing better location; results are shown in Table 4. The LCOW for the three sites in Kuwait were also shown in Table 4. The Salmi site showed minimum freshwater cost. It is worth mentioning that, the Kuwait Institute for Scientific Research (KISR) built the first renewable energy park in Kuwait in Shagaya, near Salmi.

#### 4. Conclusions

Renewable energy is a sustainable source for supplying energy for desalination. Like most renewable power generation technologies, PV systems are capital intensive but have no fuel costs. The LCOE for the studied locations ranged from 8.46 to 9.11 ¢/kWh, and the LCOW ranged from

| Direct Capital Costs          |               |                 |               |             |                        |                  |
|-------------------------------|---------------|-----------------|---------------|-------------|------------------------|------------------|
| Module                        | 294,048 units | 0.3 kWdc/unit   | 91,198.7 kWdc | 0.38 \$/Wdc |                        | \$ 34,655,500.00 |
| Inverter                      | 169 units     | 450.0 kWac/unit | 76,050.0 kWac | 0.05 \$/Wdc |                        | \$ 4,559,934.50  |
|                               |               |                 |               |             |                        |                  |
| Balance of system equipment   |               |                 | \$ 0.00       | \$/Wdc 0.20 | \$/m <sup>2</sup> 0.00 | \$ 18,239,738.00 |
| Installation labor            |               |                 | \$ 0.00       | 0.13        | 0.00                   | \$ 11,855,829.00 |
| Installer margin and overhead |               |                 | \$ 0.00       | 0.06        | 0.00                   | \$ 5,471,921.00  |
| Subtotal                      |               |                 |               |             |                        | \$ 74,782,920.00 |
| Contingency                   |               |                 |               |             |                        |                  |
| Contingency 5 % of subtotal   |               |                 |               |             |                        | \$ 3,739,146.00  |
| Total direct cost             |               |                 |               |             |                        | \$ 78,522,072.00 |

Fig. 4. Direct capital cost of PVPP in Kuwait.

| Indirect Capital Costs                  |               |                    |                      |         |  |                  |
|---|---------------|--------------------|----------------------|---------|--|------------------|
|   |               |                    |                      |         |  |                  |
| Permitting and environmental studies    |               | % of direct cost 0 | \$/Wdc 0.01          | \$ 0.00 |  | \$ 911,986.88    |
| Engineering and developer overhead      |               | 0                  | 0.08                 | 0.00    |  | \$ 7,295,895.00  |
| Grid interconnection                    |               | 0                  | 0.03                 | 0.00    |  | \$ 2,735,960.50  |
| Land Costs                              |               |                    |                      |         |  |                  |
| Land area                               | 395,024 acres |                    |                      |         |  |                  |
| Land purchase                           | \$ 0/acre     | 0                  | 0.03                 | 0.00    |  | \$ 2,735,960.50  |
| Land prep. & transmission               | \$ 0/acre     | 0                  | 0.02                 | 0.00    |  | \$ 1,823,973.75  |
| Sales Tax                               |               |                    |                      |         |  |                  |
| Sales tax basis, percent of direct cost | 0 %           |                    | Sales tax rate 0.0 % |         |  | \$ 0.00          |
| Total indirect cost                     |               |                    |                      |         |  | \$ 15,503,777.00 |

Fig. 5. Indirect capital cost of the PVPP in Kuwait.

Table 2  
PVPP analysis results in GCC countries

| Country                     | BHR             | KWT            | OMN            | QAT          | SAU                   | ARE               |
|-----------------------------|-----------------|----------------|----------------|--------------|-----------------------|-------------------|
| Location                    | Bahrain Intl Ap | Kuwait Intl Ap | Muscat Intl Ap | Doha Intl Ap | Riyadh Khalid Intl Ap | Abu Dhabi Intl Ap |
| Annual energy, GWh/y        | 173.040         | 169.449        | 170.985        | 175.046      | 173.154               | 176.449           |
| Annual energy yield, kWh/kW | 1,897.401       | 1,858.018      | 1,874.861      | 1,919.395    | 1,898.641             | 1,934.775         |
| Capacity factor             | 21.660          | 21.210         | 21.403         | 21.911       | 21.674                | 22.086            |
| Performance ratio, %        | 0.781           | 0.770          | 0.769          | 0.770        | 0.765                 | 0.769             |
| No of modules               | 294,048         | 294,048        | 294,048        | 294,048      | 294,048               | 294,048           |
| No of inverters             | 169             | 169            | 169            | 169          | 169                   | 169               |
| Installation cost, \$       | 103,343,968     | 103,342,432    | 103,346,832    | 103,345,840  | 103,343,800           | 103,345,784       |
| Installation cost, \$/kW    | 1,133           | 1,133          | 1,133          | 1,133        | 1,133                 | 1,133             |
| Size of debt, \$            | 79,833,544      | 79,833,256     | 79,833,752     | 79,833,696   | 79,833,536            | 79,833,672        |
| Size of equity, \$          | 23,510,428      | 23,509,178     | 23,513,082     | 23,512,144   | 23,510,264            | 23,512,112        |
| PPA price (year 1), ¢/kWh   | 8.354           | 8.529          | 8.459          | 8.261        | 8.348                 | 8.195             |
| PPA price (nominal), ¢/kWh  | 8.915           | 9.102          | 9.027          | 8.816        | 8.909                 | 8.746             |
| PPA price (real), ¢/kWh     | 7.353           | 7.507          | 7.445          | 7.271        | 7.348                 | 7.213             |
| LCOE (nominal), ¢/kWh       | 8.860           | 9.045          | 8.971          | 8.762        | 8.854                 | 8.692             |
| LCOE (real), ¢/kWh          | 7.307           | 7.460          | 7.399          | 7.226        | 7.302                 | 7.169             |
| Project NPV, \$             | 690,553         | 691,413        | 689,471        | 689,799      | 690,597               | 689,875           |
| NPV for PPA revenue, \$     | 111,404,128     | 111,401,488    | 111,408,680    | 111,407,336  | 111,403,976           | 111,407,200       |
| IRR target year             | 20              | 20             | 20             | 20           | 20                    | 20                |
| IRR in target year, %       | 11.00           | 11.00          | 11.00          | 11.00        | 11.00                 | 11.00             |
| IRR at end of project, %    | 13.07           | 13.07          | 13.07          | 13.07        | 13.07                 | 13.07             |

Table 3  
LCOW produced in different GCC countries

| Country                 | BHR             | KWT            | OMN            | QAT          | SAU            | ARE               |
|-------------------------|-----------------|----------------|----------------|--------------|----------------|-------------------|
| Location                | Bahrain Intl Ap | Kuwait Intl Ap | Muscat Intl Ap | Doha Intl Ap | Khalid Intl Ap | Abu Dhabi Intl Ap |
| PPA nom, ¢/kWh          | 8.915           | 9.102          | 9.027          | 8.816        | 8.909          | 8.746             |
| LCOW, \$/m <sup>3</sup> | 1.0427          | 1.0488         | 1.0463         | 1.0395       | 1.0427         | 1.0373            |

1.03 to 1.05 \$/m<sup>3</sup>, compared to 10.737 ¢/kWh and 1.101 \$/m<sup>3</sup> for the conventional CCPP.

The three key drivers of the LCOE of PVPP are:

- The capital and the installation costs of PV modules and BOS (\$/W);
- The average annual electricity yield (kWh per kW);

functions of the local solar radiation and the solar cells' technical performance;

- The finance cost of the PV system.

While desalination processes are still costly, declining renewable energy technology deployment costs are expected to bring the desalination cost down in the coming years, which is of particular interest to remote regions and

Table 4  
PVPP and LCOW in three different locations in Kuwait

| Country                     | KWT            | KWT            | KWT         |
|-----------------------------|----------------|----------------|-------------|
| Location                    | Kuwait Intl Ap | Failaka Island | Salmi       |
| Annual energy, GWh/y        | 169.449        | 176.081        | 182.421     |
| Annual energy yield, kWh/kW | 1,858.018      | 1,930.740      | 2,000.264   |
| Capacity factor             | 21.210         | 22.040         | 22.834      |
| Performance ratio, %        | 0.770          | 0.778          | 0.779       |
| No of modules               | 294,048        | 294,048        | 294,048     |
| No of inverters             | 169            | 169            | 169         |
| Installation cost, \$       | 103,342,432    | 103,342,944    | 103,341,784 |
| Installation cost, \$/kW    | 1,133          | 1,133          | 1,133       |
| Size of debt, \$            | 79,833,256     | 79,833,456     | 79,833,280  |
| Size of equity, \$          | 23,509,178     | 23,509,488     | 23,508,502  |
| PPA price (year 1), ¢/kWh   | 8.529          | 8.208          | 7.921       |
| PPA price (nominal), ¢/kWh  | 9.102          | 8.760          | 8.454       |
| PPA price (real), ¢/kWh     | 7.507          | 7.225          | 6.972       |
| LCOE (nominal), ¢/kWh       | 9.045          | 8.706          | 8.401       |
| LCOE (real), ¢/kWh          | 7.460          | 7.180          | 6.929       |
| Project NPV, \$             | 691,413        | 690,915        | 691,561     |
| NPV for PPA revenue, \$     | 111,401,488    | 111,402,888    | 111,400,896 |
| IRR target year             | 20             | 20             | 20          |
| IRR in target year, %       | 11.00          | 11.00          | 11.00       |
| IRR at end of Project, %    | 13.07          | 13.07          | 13.07       |
| LCOW, \$/m <sup>3</sup>     | 1.0488         | 1.0379         | 1.0279      |

islands with small populations and for areas of inadequate infrastructure for freshwater and electricity transmission and distribution.

## References

- [1] M.A. Darwish, H.K. Abdulrahim, A.S. Hassan, A.A. Mabrouk, PV and CSP solar technologies & desalination: economic analysis, *Desal. Water Treat.*, 57 (2016) 16679–16702.
- [2] M.A. Darwish, H.K. Abdulrahim, استخدام الطاقة الشمسية في تحلية المياه, *Al-Taqdoum Al-Almiy*, 88 (2015) 39–47.
- [3] F.E. Ahmed, R. Hashaikeh, N. Hilal, Solar powered desalination – technology, energy and future outlook, *Desalination*, 453 (2019) 54–76.
- [4] DesalData, Global Water Intelligence – DesalData, USA, 2020. Available at: <https://www.desaldata.com/> (Accessed October 15, 2020).
- [5] IAEA, Desalination Economic Evaluation Program (DEEP), The International Atomic Energy Agency, IAEA, USA, 2020. Available at: <https://www.iaea.org/sites/default/files/18/07/deep513.zip> (Accessed July 12, 2020).
- [6] I. Khamis, R.S. El-Emam, IAEA coordinated research activity on nuclear desalination: the quest for new technologies and techno-economic assessment, *Desalination*, 394 (2016) 56–63.
- [7] N. Blair, N. DiOrio, J. Freeman, P. Gilman, S. Janzou, T. Neises, M. Wagner, System Advisor Model (SAM): General Description (Version 2017.9.5), National Renewable Energy Laboratory (NREL), NREL, USA, 2018. NREL/TP-6A20-70414.
- [8] P. Gilman, SAM Photovoltaic Model Technical Reference, NREL, USA, 2015. NREL/TP-6A20-64102.
- [9] J. Freeman, Introduction to the System Advisor Model (SAM), National Renewable Energy Laboratory (NREL), NREL, USA, 2020. Available at: [https://sam.nrel.gov/images/webinar\\_files/sam-webinars-2020-intro-to-sam.pdf](https://sam.nrel.gov/images/webinar_files/sam-webinars-2020-intro-to-sam.pdf)
- [10] OneBuilding, Climate.OneBuilding, USA, 2020. Available at: <http://climate.onebuilding.org/> (Accessed August 28, 2020).
- [11] ATB, Annual Technology Baseline, National Renewable Energy Laboratory (NREL), NREL, USA, 2020. Available at: <https://atb.nrel.gov/> (Accessed October 28, 2020).
- [12] G. Owens, Best Practices Guide: Economic & Financial Evaluation of Renewable Energy Projects, Washington, DC, 2002. Available at: [https://pdf.usaid.gov/pdf\\_docs/PNADB613.pdf](https://pdf.usaid.gov/pdf_docs/PNADB613.pdf)